



R W Building Consultants, Inc.

Consulting and Engineering Services for the Building Industry

P.O. Box 230 Valrico, FL 33594 Phone 813.659.9197 Facsimile 813.659.4858

ENGINEER'S NOTICE OF EVALUATION # TTF-258F

Therma-Tru Corp.
108 Mutzfeld Road
Butler, IN 46721
Phone 260.868.5811 Facsimile 260.868.5190

DESCRIPTION OF UNIT

Model Designation: Fiber Classic/ Smooth Star, Series Fiberglass Door (Glazed) with or without Side-lites

Maximum Overall Nominal Size: up to 8'4 x 8'0 Usable Out-swing Configurations: X, OXO, XO, OX, XX & OXXO

General Description: The head and jambs are wood measuring 4.5" x 1.25" with an extruded aluminum threshold. The door panels and sidelite panels are 1.68" thick and consist of two SMC skins with a thickness of 0.110" for the Fiber Classic Series or the Smooth Star Series with a skin thickness of 0.070". Skins are glued to wood stiles and rails with a urethane core. The glazed sidelites are routed to receive 1/8" tempered or 1/2" insulated tempered lip lite inserts or integral flush glazed lites manufactured by Therma-Tru.

FBC Section 1707 Materials and Assembly Tests: (1707.4.3 Exterior Door Assemblies; 1707.4.5 Mullions Door Assemblies)

Test	Description	Test Location	Date	Report No.	Certifying Engineer
ASTM E330	Uniform Static Air Pressure	NCTL - Orlando	May 30, 1997	210-1940-1234	Barry Portnooy, #16258
		ETC - Rochester, NY	June 22, 2001	ETC-01-741-11008.0	Joseph Dolden, P.E. #42929
TAS 202	Forced Entry	NCTL - Orlando	May 30, 1997	210-1940-1234	Barry Portnooy, #16258
		ETC - Rochester, NY	June 22, 2001	ETC-01-741-11008.0	Joseph Dolden, P.E. #42929
ASTM E331	* Water Penetration	NCTL - Orlando	May 30, 1997	210-1940-1234	Barry Portnooy, #16258
		ETC - Rochester, NY	June 22, 2001	ETC-01-741-11008.0	Joseph Dolden, P.E. #42929
ASTM E283	Air Infiltration	NCTL - Orlando	May 30, 1997	210-1940-1234	Barry Portnooy, #16258
		ETC - Rochester, NY	June 22, 2001	ETC-01-741-11008.0	Joseph Dolden, P.E. #42929
TAS 201/203	**Large Missile Impact/Cycling	N/A	N/A	N/A	N/A

* Sidelites are considered a window and meet 15% of Positive Design Pressure water infiltration criteria.

**This product must be shuttered to meet windborne debris criteria.

Design Pressure Ratings:

Configuration	Maximum Size	Design Pressure Ratings	
Glazed Single X	Up To 3'0 x 8'0	+ 47.00 - 47.00	
Glazed Single with Sidelites XO, OX, OXO	Up To 5'4 x 8'0	+ 47.00 - 47.00	
		Alum Astragal	Constal Alum Astragal
Glazed Double XX	Up To 6'0 x 8'0	+ 40.00 - 40.00	+ 47.00 - 47.00
Glazed Double with Sidelites OXXO	Up To 8'4 x 8'0	+ 40.00 - 40.00	+ 47.00 - 47.00

Installation and Anchoring: See reverse side this page

Use

1. Evaluated for use in locations adhering to the Florida Building Code and where pressure requirements as determined by ASCE 7 Minimum Design Loads for Buildings and Other Structures do not exceed the design pressure ratings listed above.
2. For Masonry installations where the sub-buck is less than 1-1/2 inches (FBC section 1707.4.4 Anchorage Methods and sub-sections 1707.4.4.1 and 1707.4.4.2) same diameter Tapcon type concrete anchors must be substituted and the length must be such that a minimum 1-1/4" engagement of the Tapcon into the masonry wall is obtained.

Certification: Florida Professional Engineer - Seal No. 43409

May 22, 2002

Lyndon F. Schmidt

19506 French Lace Drive

Lutz, FL 33558

Therma-Tru® FiberClassic / Smooth Star Out-swing Fiberglass Door

Maximum Size Up To 8'4 x 8'0

